ARAVALI POWER COMPANY PRIVATE LIMITED

INDIRA GANDHI SUPER THERMAL POWER PROJECT

JHAJJAR

AC Transmission Line/ ICT/ Static Compensator/ Series Compensator/HBDC (Back to Back Station and Bi Pole Links)/Rectors/Bus Reactors Outage Details For Month Of

Sr. No	EVENT NO.	Month	ELEMENT NAME	OUTAGE	RESTORATION	DURATION OF OUTAGE ATTRIBUTABLE TO				REASON OF OUTAGE	% Availability	Remarks
				DATE TIME	DATE TIME	Inter state Transmisssion Licensce	OTHERS	System constraint/ Natural calamity/ Militancy	Deemed Available			
						@ (T)	# (U)	& (C)	* (D)			
						Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min			
1	1	Apr-24	JHARLI(APCPL) -MUNDKA (DTL)-CIRCUIT 1	10-04-2024 14:12	10-04-2024 18:10	03:58				Zone-1 Earth Fault	99.72	NRPC certified
2	2	May-24	JHARLI(APCPL) -MUNDKA (DTL)-CIRCUIT 2	27-05-2024 14:36	27-05-2024 20:48	06:12				Line tripped on Z1 E/F	99.58	NRPC certified
3	3	Jun-24	JHARLI(APCPL) -MUNDKA (DTL)-CIRCUIT 1	26-06-2024 09:29	26-06-2024 19:21	09:52				Emergency Shutdown Availed by APCPL for Line Isolator Arm Replacement	99.31	NRPC certified
4	4		JHARLI(APCPL) -MUNDKA (DTL)-CIRCUIT 1	13-06-2024 10:06	13-06-2024 14:39		04:33			Shutdown Availed by Mundka from Breakdown Restoration		
5		Jul-24									100.00	NRPC certified
6	5	Aug-24	JHARLI(APCPL) -MUNDKA (DTL)-CIRCUIT 2	05-08-2024 15:41	05-08-2024 18:40		02:59			Emergency Shut down availed by DTL Mundka	100.00	NRPC certified
7		Sep-24									100.00	NRPC certified
8	6	Oct-24	JHARLI(APCPL) -MUNDKA (DTL)-CIRCUIT 1	18-10-2024 07:51	18-10-2024 19:10		11:19			AOH SD availed by APCPL	91.46	NRPC certified
9	7		JHARLI(APCPL) -MUNDKA (DTL)-CIRCUIT 2	19-10-2024 07:48	19-10-2024 19:34		11:46			AOH SD availed by APCPL		
10	8		JHARLI(APCPL) -MUNDKA (DTL)-CIRCUIT 1	21-10-2024 08:21	21-10-2024 19:45		11:24			AOH SD availed by APCPL		
11	9		JHARLI(APCPL) -MUNDKA (DTL)-CIRCUIT 2	22-10-2024 10:21	22-10-2024 19:53		09:32			AOH SD availed by APCPL		
12	10		JHARLI(APCPL) -MUNDKA (DTL)-CIRCUIT 2	24-10-2024 07:14	24-10-2024 21:04		13:50			AOH SD availed by APCPL		
13	11		JHARLI(APCPL) -MUNDKA (DTL)-CIRCUIT 1	25-10-2024 08:02	25-10-2024 19:27		11:25			AOH SD availed by APCPL		
14	12		JHARLI(APCPL) -MUNDKA (DTL)-CIRCUIT 2	26-10-2024 07:18	26-10-2024 19:26		12:08			AOH SD availed by APCPL		
15	13		JHARLI(APCPL) -MUNDKA (DTL)-CIRCUIT 1	27-10-2024 07:13	27-10-2024 18:27		11:14			AOH SD availed by APCPL		
16	14		JHARLI(APCPL) -MUNDKA (DTL)-CIRCUIT 1	28-10-2024 07:04	28-10-2024 19:18		12:14			AOH SD availed by APCPL		
17	15		JHARLI(APCPL) -MUNDKA (DTL)-CIRCUIT 2	29-10-2024 07:35	29-10-2024 19:09		11:34			AOH SD availed by APCPL		
18	16		JHARLI(APCPL) -MUNDKA (DTL)-CIRCUIT 1	30-10-2024 08:41	30-10-2024 19:18		10:37			AOH SD availed by APCPL		
19	17		JHARLI(APCPL) -MUNDKA (DTL)-CIRCUIT 1	07-10-2024 12:00	07-10-2024 18:13		06:13			Shut Down Availed by Mundka (DTL)		
20	18		JHARLI(APCPL) -MUNDKA (DTL)-CIRCUIT 2	08-10-2024 14:57	08-10-2024 19:49		04:52			Shut Down Availed by Mundka (DTL)		
21		Nov-24									100.00	NRPC certified
22	19	Dec-24	JHARLI(APCPL) -MUNDKA (DTL)-CIRCUIT 1	11-12-2024 07:52	11-12-2024 19:51	11:59				Shutdown Availed by APCPL for Line PM	99.19	As per APCPL data (NRPC certification awaited)
23		Jan-24									100.00	
24		Feb-24									100.00	
25		Mar-24									100.00	

II **Elements where restoration time has exceeded the standards specified in Regulation 5(b)**

Element Name	Restoration time as specified in Regulation 5 (b) Nos of days	Actual Restoration Time
NIL		

III Details of Compensation paid by the Inter-

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5 (b)		Compensation paid (Rs)
	% Availability Prescribed	% Actual Availability	Restoration time prescribed (in days)	Actual Restoration time (in days)	
NIL					

Month	Dependability Index D=NC/NC+NF	Security Index S=NC/NC+NU	Reliability Index R=NC/NC+NI
Apr-24	1	1	1
May-24	1	1	1
Jun-24	1	1	1
Jul-24	1	1	1
Aug-24	1	1	1
Sep-24	1	1	1
Oct-24	1	1	1
Nov-24	1	1	1
Dec-24	1	1	1
Jan-25	1	1	1
Feb-25	1	1	1
Mar-25	1	1	1